



AVERAGE LOSS OF WATER LEAKING FAUCETS OVER A PERIOD OF ONE MONTH




30
DROPS
PER
MINUTE

54
GALLONS
PER
MONTH




60
DROPS
PER
MINUTE

113
GALLONS
PER
MONTH




120
DROPS
PER
MINUTE

237
GALLONS
PER
MONTH



1014
GALLONS
PER
MONTH



2202
GALS.
PER
MONTH

Small continuous leaks will waste large amounts of water. In addition, leaks in hot-water lines will waste heat. Keep all valves and faucets tight. When a leak develops, replace faucet washers. If valves or faucets are damaged, replace faucet or valve assembly.